4648108085

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Fox DATE 10-2-09 PERMIT NO.

PHONE: Business Home

LOCATION I-40 west TR on Hutts Rd Take next right lot on left at end of Rd S. R. No. 1376

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Sandy clay loam + clay
Percolation Rate Soil borings
Topography Slope
Depth to Water Table 10'+
Rock or other impervious formations none




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Larry Turkey

IMPROVEMENTS PERMIT BY J. C Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-7-09

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

4648108085

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Fox DATE 10-3-77 PERMIT NO.

PHONE: Business Home

LOCATION 150 west JR on Stutts Rd Take next right Lot on left at end of Rd S.R. No. 1397

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3 Character & Porosity of Soil Sandy clay loam + clay


Garbage Disposal Unit Yes (–) No (✓) Percolation Rate Soil borings

Auto. Dishwasher Yes (–) No (✓) Topography 3% Slope

Auto. Wash Machine Yes (✓) No (–) Depth to Water Table 10' +

Site Suitable Yes (✓) No (–) Rock or other impervious formations none

Lot Area 3½ acre




Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Larry Tucker

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-5-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White – Inspection Dept. Copy: Yellow – Sanitarian's Copy: Pink – Owner's Copy: Gold