

MICHAEL ATHANAS & ASSOCIATES
LICENSED SOIL SCIENTIST
561 Ennis Rd.
Weddington, NC 28173
(704) 576-3887

OK Lwd


APPROVED JUN 0 1 2015

Reference: Data Sheet for 116 McInnis Rd.
House Footprint: See attached plan
Building Setbacks: 35' front, 15' side, 50' lake
Water Source: Existing well
Number of Bedrooms: 3/360 GPD
Predetermined LTAR: See existing permit
Proposed System Type: Existing Conventional Bed
Proposed Repair System Type: N/A
Distribution: Gravity
Septic Tank Size: 1000 gallons
Proposed Trench Bottom: N/A

Line	Design Length	Actual Length
Existing Bed		

Initial System: **Repair System:**

Comments:
This property has an existing conventional bed permitted for a 3 bedroom residence. The system has been probed and marked in the field. The system has also been picked up by the surveyor.



Lance D. Schamback, PLS
LICENSE NUMBER: L-4295

OK LHD

APPROVED JUN 01 2015

LINE TABLE		
LINE	LENGTH	BEARING
L1	6.54	N80°20'20"W
L2	10.00	N20°12'20"W
L3	46.50	N20°12'20"W
L4	40.01	S00°24'19"W
L5	3.20	N74°29'40"E

Legend

B.O.C. = Back of Curb
E.O.P. = Edge of Pavement
R/W = Right-of-way
I.P.S. = #4 Rebar Set
= Not to scale
= Telephone or Cable Pedestal
= Utility Pole
= Light Pole
= Guy Wire

Notes:


1) This property may be subject to any Easements, Rights-of-way, and/or Restrictive Covenants.
2) Boundary information based on Map Book: 10 at Page: 26 as recorded in the Iredell County Register of Deeds.
4) This survey is of an existing parcel or parcels of land.
5) No N.C.G.S. or U.S.G.S. Monuments could be located within 2000'.
6) Area by coordinate method.

GRAPHIC SCALE

50 0 25 50 100

(IN FEET)
1 inch = 50 ft.

Vicinity Map



Plot Plan

FOR

Furr Residence

SCALE: 1" = 50

FIELD BOOK:

FILE: 2014-33PLOT