4648144054

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Vance Smith DATE 2-6-07 PERMIT NO. 10

PHONE: Business _____ Home _____

LOCATION Smith Rd. 1295 Troutman
1412 Jerusalem left S. R. No. 1412

SUBDIVISION NAME Duke Power LOT NO. 46 SECTION OR BLOCK NO. 1


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Lot Area one acre

Character & Porosity of Soil Cecil sandy loam
Percolation Rate 30 min/in
Topography 2% slope
Depth to Water Table 4 ft
Rock or other impervious formations Decomposed granite



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 200
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )

Installed by Hardin Backhoe

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Well & pump

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 2-23-07

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold