**IREDELL COUNTY HEALTH DEPARTMENT**
**ENVIRONMENTAL HEALTH DIVISION**
**Application For Improvement Permit**
**Site Plan Form**


---

INSTRUCTIONS TO APPLICANT: (Items in Parentheses are to be performed by DEVELOPERS ONLY)

All property corners must be staked and flagged with dimensions matching those shown on an approved final (preliminary) plat (**and** proposed house dimensions must be staked and flagged) before the Iredell County Health Department can begin review work on this proposed site. An application for an Improvement Permit is considered complete **only** when this site plan form is completed, signed, and attached to the application form.

---


**As Close To Scale As Is Possible:** 1. Draw in the proposed lot showing **all** proposed lot dimensions and orientation to proposed streets or roads. 2. Draw in the proposed structure showing dimensions and distances to property lines (include decks, walkways, etc.). E. Draw in the proposed driveway location. 4. Draw in all wells, both existing and proposed, including those on adjacent property (if known). 5. Draw in any other structure ie. sheds, outbuildings, pools, etc. which will occupy space on the proposed lot.




I hereby convenant that the above representation is correct to the best of my knowledge and ability.

10.21.93 Date Michael Krom SIGNATURE OF OWNER/AUTHORIZED AGENT

MILLS FOREST LOT 3 II




THIS LOT WILL ACCOMODATE LPP ORIGINAL AND REPAIR SYSTEMS. THE DEVELOPER I.P. WILL BE ISSUED FOR THIS. THE LOT MAY BE REEVALUATED AFTER BEING SURVEYED AND UNDER-BRUSHED.

* AN ALTERNATE LAYOUT WOULD BE TO PLACE THE WELL AT THE VERY REAR AND CENTER, MOVE THE HOUSE BACK TO ABOUT 60' OFF REAR PL AND PUMP TO THE FRONT. THE WELL ON LOT 2 COULD BE MOVED WESTWARD (CLOSER TO LOT 1) TO REDUCE THE SETBACK RADIUS ON LOT 3. THIS LAYOUT MAY POSSIBLY ALLOW FOR A CONVENTIONAL ORIGINAL SYSTEM AND LPP REPAIR.

1" = 50'