IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Fee MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 129406 PIN# 4648 23 4511 DATE Sept 2, 2005

OWNER OR CONTRACTOR Ward Diversified Services / Greg Hamm PHONE: Business _____ Home _____

ADDRESS 8156 Monroe Rd, Catawba, N.C. 28609

LOCATION 150 W. TR Bluefield Rd. TL Big Indian Loop TR Palos Verde Dr. 5th lot on left

SUBDIVISION Palos Verde BLOCK / SECTION _____ LOT 6 LOT AREA 26,229 ft² SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .025

Septic Tank: 1000 Gallons; STB 794 Date 3-4-06

Pump Tank: 1000 Gallons; PT 283 Date 6-13-06

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 640/960 Linear Feet 320

No Lines 4 @ 80' Trench Width 24" min 36" max Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, (IV) V, VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms _____

☐ Business No. Employees _____

☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

OR 36" max 96cc

"Shave off" old burms

Initial site evaluation and layout performed by Mike Athanas, LSS and Ashley Rollins, LSS.

Comments:/Conditions:

INITIAL SITE SKETCH

SEE Plan by Mike Athanas & Ashley Rollins

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 9-28-05 Installed by: Specialty Septics (Jamie O'Daniel)

Improvement Permit by: _____ date 9-2-05 Operation Permit by: Wesley Perkins R.S. date 4/5/07

Authorization to Construct by: _____ date 3/8/06 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK