4648240084

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold Sanders DATE 7-24-96 PERMIT NO. 2357

PHONE: Business _____ Home _____

LOCATION Hwy 21 to Fletcher Rd TR on left 4th house on left

SUBDIVISION NAME Pebble Meadows S. R. No. _____

LOT NO. 52 SECTION OR BLOCK NO. 2


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area 1.01 acres

Character & Porosity of Soil Sandy Clay loam Porosity good
Percolation Rate 30 min/inch
Topography Gently sloping
Depth to Water Table 24" to 36" in the lowest
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 24"
Water Supply: Individual ( )
Public ( )

Installed by E. T. Ervin

IMPROVEMENTS PERMIT BY T. C. Wade

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold