IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 122963 PIN# 4648 24 8353 DATE 1/24/09

OWNER OR APPLICANT Lee Cutler PHONE: Business Home 704-660-6576

ADDRESS 107 Wilton Pl. Mooresville, NC. 28117

LOCATION 15 W TR BLUEFIELD RD TL BIG INDIAN LP STRAIGHT ON (L) #595

SUBDIVISION CL+T BLOCK / SECTION 12 LOT 58 LOT AREA ~.66AC SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1017 Date 3/2/07
Pump Tank: 1000 Gallons; PT 17 Date 5/22/07
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 400-600 Linear Feet 200
No Lines 2@100' Trench Width 2-3' Max Trench Bottom Depth 3'


[X] New System [ ] Repair [ ] Expansion System Type: I II III (IV) V VI
System Description: Pres Dosed - 16" APBPS
Repair System Description: Same Type
Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home No. Bedrooms 3
[ ] Mobile Home No. Persons
[ ] Business No. Employees
[ ] Other

Water Supply: [X] Individual [ ] Public [ ] Community


Gravel Depth No [ ] Gravity [X] Pressure [ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: 175.81



Comments:/Conditions: 1 - EXISTING MUST BE PROPERLY ABANDONED BEFORE SYSTEM INSTALLATION 2 - NEW WELL LOCATION

Turbo, Pressure, Living, Valves



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date 2/2/07

Improvement Permit by: Wesley Sparks RS. date 1/26/07

Authorization to Construct by: Wesley Sparks RS date 1/26/07

Installed by: C+S Backhoe + Grading

Operation Permit by: Wesley Sparks RS date 11/14/09

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK