4648-24-8971

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Steel DATE 6-15-18 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 W Iron 1395 TL on 1395 Iron 1462

SUBDIVISION NAME ✓ Lake Norman (CL+T) LOT NO. 68 ✓ SECTION OR BLOCK NO. 12 ✓ S. R. No. _____

Site Address: 116 Churchill Ln. - MVL

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	(✓)	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Clay loam


Percolation Rate 60 min/in

Topography 2-5% Slope

Depth to Water Table 6 to 8'

Rock or other impervious formations None

Lot Area 1.0 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10 +-

Water Supply: Individual (✓)

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold