07841

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gary Graham DATE Jan 21, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 W to Bluefield to Bearfoot to into Bearfoot Bay ~1/8 mile on Rt S. R. No. _____

SUBDIVISION NAME Bearfoot Bay LOT NO. 849 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Lot Line (✓) No ( )

Lot Area ~1½ ac

Character & Porosity of Soil clay

Percolation Rate 2.3

Topography 4-8% comply (old terraces to be removed)

Depth to Water Table ~36"

Rock or other impervious formations none obs.

_____ Basement with Plumbing | ✓ PARTIAL Basement without Plumbing _____ No Basement

Size of Tank 1500 Gals.

Nitrification Field:


No. of Lines 4

Sq. Ft. 1600 Linear Ft. 533

Depth of Stone in Lines 12"

Water Supply: Individual (✓) Public ( )

270' of 6" "A" pipe



Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Walter Pratherton

IMPROVEMENTS PERMIT BY David R. Hinson, RS.

COMMENTS: Install drainfield no deeper than 24" to bottom of ditch and on contours. Install "French" drain 1 foot deeper than nitrification field and discharge to back of property. 10-6-88 Approved drainfield installed DRH

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

10-18-88 French drain eliminated. DRH