DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Debra Sousa
ADDRESS: _____
PROPOSED FACILITY: _____
LOCATION OF SITE: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

APPLICANT: _____
APPLICATION DATE: _____
PROPOSED DESIGN FLOW (.1949): _____
DATE EVALUATED: 1/7/97
PROPERTY SIZE: _____
PROPERTY RECORDED: 1/8/97

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	2-4% LL	0-20"	Rd/Brn C/CL	m-f SBK SS-S, SP-P, SE, FI-FR					PS .3
		20-48"	Rd/Brn C	m-f SBK SS, SP, SE, FR					
		W	SAP inclus						
2	2-4%	0-20"	Rd/Brn C/CL	m-f SBK SS-S, SP-P, SE, FI-FR					PS .3
		20-48"	Rd/Brn C	m-f SBK SS, SP, SE, FR					
			Common Mica flakes & SAP inclus						
3		0-43"	Rd/Brn C/CL	m-f SBK SS, SP, SE, FI-FR					PS .3 to 43"
			w/ Inclus of SAP; Common Mica flakes						
		43-48"	SCL/SL Yel/Brn SAP	FR					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____