DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____
ADDRESS: _____ APPLICANT: _____
PROPOSED FACILITY: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-22-04
LOCATION OF SITE: Lot 17 Cedarwoods PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-7	wk sbk brn scl	fr sss p	few fine gleam mottles				.25
		7-24	m-wk sbk R brn c	fr sp sss p					.3
		24-56	wk f sbk yr cl	fr sss p	few mod sap				
2		0-25	Compacted scl/c	fi-vfi					4
		25-55	wk-m f sbk rd/cl	few-common mod sap	fi fr sp sss p			.25-.3	
3		0-14	Compacted scl/c	vfi					.25-.3
		14-20	m f sbk rc	fr sss p					@ 14"
		20-45	wk f sbk rc	fri s ste p					
		45-58	wk f sbk yr cl	fr sss p few common mod sap					
4	6-8%	0-16	wk f sbk yr c	fr sss p					.3+
		16-33	BG wk f sbk R cl	fr sss p common mod sap					
		33-56	wk f sbk Rg cl sap	fr sss p					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	6 Conv PRBPS	2 PPPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH Hampton
OTHER(S) PRESENT: Ken Hennings