4048340247

IV

IREDELL COUNTY HEALTH DEPARTMENT

10331

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Sands DATE June 13, '90 PERMIT NO. 2P-6-A-59

PHONE: Business _____ Home _____

LOCATION 15 W TR 1467 (Bluefield Rd.) TL 1395 (Beaufort Rd.) TR at Lake onto Big Indian Loop ± 3/4 mile on Left S. R. No. _____

SUBDIVISION NAME CLAT Lake Norman LOT NO. 1069 SECTION OR BLOCK NO. 12

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area 1.11 AC

Character & Porosity of Soil Cecil clay
Percolation Rate 1"/35'
Topography ± 6%
Depth to Water Table 4ft
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1035 ± Linear Ft. 345 ±
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( ).

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Lot Line

Big Indian Loop

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well not installed.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold