4048 343 2866

1965

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Hildreth DATE May 21, 1990 PERMIT NO. ZP-6-A-60

PHONE: Business _____ Home _____

LOCATION 150 W TR 1467 TL 1395 Bearsfoot TR Big Indian Loop ~1 mi on right after crossing creek S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 1268 SECTION OR BLOCK NO. 12

House(✓) Mobile Home ( ) Business ( ) Other Permit now for garage 1 Bdr → Future House

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area 1.78 ac Lot

Character & Porosity of Soil clayey


Percolation Rate N. 3 gpd/sqft

Topography 1-5% + 3½'

Depth to Water Table _____

Rock or other impervious formations none obs.

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System Big Indian Loop

1250 FT

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3@67'

Sq. Ft. _____ Linear Ft. 200'

Depth of Stone in Lines 1 & 1

Water Supply: Individual (✓) 16"

Public ( ) Lake

Installed by F J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well not installed at time of issuance of operation permit for septic tank system

CERTIFICATE OF COMPLETION BY Sam Ingram EOH-S DATE May 21, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH RULES AND REGULATIONS.

Permit is VOID if any unauthorized changes are made in the Improvements Permit.

The proposed / existing Screen Porch addition does not appear to impact the existing septic system

**NOTE: Building Addition must be at least 5ft from Septic

Maria Watson REHS

Date: 9/13/2011

ICHD-Environmental Health Division

Health Dept. Copy: White Inspector: Gold