* 4/2/92 - Completed Drainlines 4@50'x21

13891

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Steve Rottmen DATE 1/10/92 PERMIT NO. 2P-6-A-74

PHONE: Business _____ Home 704 483-3580

LOCATION Big Indian Lp.; 1st entrance around sharp curve to ~1/4 mile on (R)

S.R. No. _____

SUBDIVISION NAME CL+T LOT NO. 74 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other Pressure Panel System

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area Existing

Soil Characteristics P - C + TRANS


Application Rate P. : 1

Topography 2 on

Depth to Water Table > 48"

Rock or other impervious formations 5 - NONE OBSERVED

☑ Basement with Plumbing ☐ Basement without Plumbing ☐ No Basement ☐ Crawl Space



Size of Tank Existing 1000 1000 A/T Gals.

Nitrification Field:

No. of Lines 4@50'x3'

Sq. Ft. _____ Linear Ft. 200 *

Depth of Stone in Lines N/A 6" SAND

Water Supply: Individual ☐ Public ☐

* 16" Prefabricated Permeable Panel Blocks

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

*Signed _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Wesley Sparks R.S.

COMMENTS Pressure dosed APBS drainline system. 1 1/4" PVC line with 1 (3/16") hole drilled per panel with 2' standpipe at end of each drainline. 50' seperation from all drilled wells and 10 feet from all property lines at this site.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold