IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. R. Patterson DATE 6-24-76 PERMIT NO. 165

PHONE: Business _____ Home 537-7066

LOCATION 150 w. TR on 1305 TL on 1315 TR on 1442 1 mi on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 75 SECTION OR BLOCK NO. 12

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate Not Taken

Topography 20% slope

Depth to Water Table 6' to 8'

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250'

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hubert Grading

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 6-24-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold