9465

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C) 4648352178

OWNER OR CONTRACTOR Larry Penn DATE 9/20/89 PERMIT NO. 2P-6-A-71

PHONE: Business _____ Home _____

LOCATION 150 W. TR. Bluefield TL Big Indian Loop TR Big Indian Loop. S. R. No. _____

SUBDIVISION NAME C L and T LOT NO. 1063 SECTION OR BLOCK NO. 12


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	3 gpd/ft+2
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

PT: 1000

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. _____ Linear Ft. 200' of

Depth of Stone in Lines 16" T and J

Water Supply: Individual (✓) Panels.

Public ( )

Installed by Cedarwood Septic Tank
Tim Smith (Rowan Co.)

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP w/DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C Price, R.S. DATE 9/20/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold