5465

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Penn DATE 2/6/89 PERMIT NO. _____

PHONE: Business _____ Home _____ 483-4034 @ work

LOCATION 150 W. TR Bluefield TL Barefoot TR Big Indian Loop ~ 1mi on R. S. R. No. _____

SUBDIVISION NAME C L and T LOT NO. 1063 SECTION OR BLOCK NO. 12

2P-6-A-71

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay

Percolation Rate .3 gpd/ft²


Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

Lot Area 20000 ft² +

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement P.T. 1000 gal



Plot of System (NOT TO SCALE)

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 200' of
Depth of Stone in Lines 16" T and J
Water Supply: Individual (✓) panels.
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Larry O Penn

IMPROVEMENTS PERMIT BY Andre C Pierce

COMMENTS: Install T and J panel drainfield at minimum depth (28") in order to stay in good soil. Total # of panels = 46. Total flow = 1886 (1 = 9 minutes for cycle.) TDH = ~20-25 Use Sch. 40 PVC. 2" pumpline and reduce to 1¼"

CERTIFICATE OF COMPLETION BY PVC. in panels themselves PVT DATE _____

EXISTING SYSTEM CHECKED BY: 1 5/32" hole in ea. panel. DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit. High water alarm will be mounted and functional before completion certificate is issued.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold