Division of Environmental Health
On-site Wastewater Section

Property ID:
Lot #:
File #:
AppID:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: BRUCE STROUP
Address: PO BOX 1 KANNAPOLIS, NC 28082
Proposed Facility: SFR Design Flow (.1949) 360
Location of Site:
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [ ] Auger Boring [X] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

Applicant:
Date Evaluated:
Property Size:
Property Recorded:

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	b PROFILE FACTORS 1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	Profile Class & LTAR
1	10%	0-10	ORGANIC						
		10-36	CL,M,SBK	SS,SP,SEXP					
		36-48	C,M,SBK	SS,SP,SEXP		48"			.3
2	9%	0-10	ORGANIC						
		10-28	CL,M,SBK	SS,SP,SEXP					
		28-48	LSAP,W	NS,NP,NEXP		28"			.35
3	10%	0-8	ORGANIC						
		8-39	CL,M,SBK	SS,SP,SEXP					
		39-48	CL,M,SBK	SS,SP,SEXP	MANY MICA	48"			.3

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)	GRAVITY PB	LP PANEL BLOCK
Site LTAR	.3	.3

Other Factors (.1946):

Soil Evaluation By: BEN ALDRIDGE

Others Present: EDDIE AND LARRY BEAM

Site Classification (.1948): PS

Site Evaluation By: BEN ALDRIDGE

Others Present: EDDIE AND LARRY BEAM