DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 25-6-A-1
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Ronald W. Presnell OWNER: ✓ AGENT: PHONE:
ADDRESS: 2901 Oakwood Dr. APPLICATION DATE: 7/9/93 DATE EVALUATED: 7/9/93
Charlotte, N.C. PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE:
LOCATION OF SITE: Judas Rd. (from Cornelius Rd 1st lot on Rt.)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-23"	sbk c	1:1 fi-fr.	—	—	PS	—	.4
		23-44"	wk sbk cl	1:1 fr.	—	—	PS	—	.35
2									
3									
4									
5									

AVAILABLE SPACE (.1946): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35 gal/sq ft/day
EVALUATED BY: [signature] PS OTHER(S) PRESENT: Ronald Presnell
COMMENTS: