DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 29 A 8
PROPERTY RECORDED: No
COUNTY: IR.

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CW BROTHERTON OWNER: ✓ AGENT: PHONE: —
ADDRESS: R+4 BOX 382 APPLICATION DATE: 7/2 DATE EVALUATED: 7/2/93
MVLLE PROPOSED FACILITY: 3BD - 2SA DW MOBILE HOME
PROPERTY SIZE:
LOCATION OF SITE: BLUEFIELD RD, ON (R) AFTER X CREEK
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	P 7-10%	0-5	GR. / 2	1:1	SS/F/L	S	S	N/A	
		6-16	SB/C	1:1	S/H/SP	S	S	N/A	
		17-26	SB/C	1:1	S/H/F	S	S	N/A	
		26-39	wkSBK/C	1:1	SS/P/F	S	S	N/A	
		40-46	SBK-G/C	1:1	SS/SP/F	S	S	II	.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: SPARKS OTHER(S) PRESENT: MIKE BROTHERTON
COMMENTS: TRICKY CONTOURS - TRENCH DEPTH 30-32" MAX.
PRESSURE CONV. REPAIR UPSLOPE FROM ORIGINAL SYSTEM