IREDELL COUNTY HEALTH DEPARTMENT 4648799873

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray W. Robinson DATE 3-5-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115-21 TL past Sheperds School on to 1309 (Barfield) on left at end behind house S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	.4 gal/ft²/day 6-8"D	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
			Rock or other impervious formations	none obs	

Lot Area 20,000 ft²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
( ) No. of Lines 3
( ) Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓) well next door
Public ( )

Installed by Wes Litton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY David Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Barnett DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

3:00-3:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy W. Robinson DATE 10-20-86 PERMIT NO. 439

PHONE: Business _____ Home _____

LOCATION 115-21 N. TL past Shepherd's School onto 1309 (Barfield) on left at end behind home S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-8%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4+	
			Rock or other impervious formations	none obs.	

Lot Area 20000 sq ft

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )
Well at home

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Ray W Robinson

IMPROVEMENTS PERMIT BY David G. Hyman, RS

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold