DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kingdom Hall
ADDRESS: ___ APPLICATION DATE 6/14/04
PROPOSED FACILITY: Church - 1875 Seat PROPOSED DESIGN FLOW (.1949): 1000 GPD DATE EVALUATED: 7/15/04
LOCATION OF SITE: Cornline Estates - Lot 45 PROPERTY SIZE: 4 Ac
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other PROPERTY RECORDED: ___
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	CC L 5-9% w wicg	0-18	sbk / cl	Fi SS - SP	PS / 4R				
		19-32	wk / lcl	FR - SS - SP.					
		33-48	wk / mic. cl	FR SS - SP					
2	"	0-24	BR / scl	FR SS - NP					
		25-49	sbk / Fi scl						
3	" CC	0-12	BR / sl	VFR NS - NP	PS / 10YR				
		13-29	sbk / mic. cl	FR - SS - SP	PS / R				
		30-49	wk / scl	FR SS - SP	PS / RB				
4	L Rem 9-12% o	0-13	GR / l	VFR SS - NP					
		14-31	wk sbk / scl	Fi - SS - SP					
		32-49	wk Fi sbk / sc	Fi SS - SP.					.3 .3

Rem Rem

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	
System Type(s)	Trench / Pressure Dosed / LPP3	Same
Site LTAR	.3	

OTHER FACTORS (.1946): Pressure Dosed - Flow Equalized
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: D Parks
OTHER(S) PRESENT: Jerry Hrosechuk

COMMENTS: See Topo Map