DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___
4648 96 9173

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Brian Smith APPLICANT: Same
ADDRESS: 104 Larkhaven Mound. APPLICATION DATE: 11/23/08 DATE EVALUATED: 11/03
PROPOSED FACILITY: 3 BD House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~.76
LOCATION OF SITE: 143 Olympia Dr. PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS ~cc 5-8%	0-6	sbk - sl	FR SS NP	PS	S	PS		
		7-31	wsbk - cl	FR SS SP					
		32-49	MMsbk tcl	FI SS SP					
2	SS 7-9%	0-5	FSbk scl	FR NS NP					
		6-30	wsbk cl	Fr SS SP	PS	S			
		31-50	MFSbk tcl	FR SS NP	PS 1-CH3	S	PS		
3	L 7-9%	0-6	FSbk scl	FR NS NP	S		N/A		
		7-29	MM cl	FR SS SS	S				
		30-48	MM tcl	Fr SS SP	PS FRINT 2CH3 GR	S	PS		
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	T 25%	LP - RPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): House Size
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: Sparks
OTHER(S) PRESENT: ___