DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shupe APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: Mobile 76x28 PROPOSED DESIGN FLOW (.1949): 490 PROPERTY SIZE: 1.14 Ac
LOCATION OF SITE: Dorothy Lane - Lot 10 Woodhills PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	3% ncl	0-18	GR / l ~ cl	FR SS SP					
		21-38	sbk / cl	FR SS SP					
		39-50	GR / scl	FR NS NP					
2	CVL ~4%	0-12	SBK / cl	FR SS SP					
		13-27	SBK / hcl	FR SS SP					.3
		28-40	SBK / cl SAP	VFR SS NP					
		41-49	GR / l SAP	VFR SS NP					.35
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	5	5
System Type(s)	111	101
Site LTAR	.3	.3

OTHER FACTORS (.1946): Top little ec w areas
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Sparks
OTHER(S) PRESENT: _____