IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134419 PIN# 4649 04 9474.002 4649 04 7575 DATE October 16, 2006

OWNER OR APPLICANT Orchard Farms LLC / Pride PHONE: Business Home

ADDRESS 271 Hideaway Lane, Mooresville, N.C. 28117

LOCATION Perth Rd. (NB) past Jordan Rd. TR West Cherry Lane TL Orchard Farms Lane 2nd lot on left

SUBDIVISION The Orchard BLOCK / SECTION LOT 2 LOT AREA 25,526 FF SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1017 Date 3/19/07

Pump Tank: 1000 Gallons; PT 17 Date 9/20/07

Pump Make: Bowlas Model ~~INSTA-FLO~~ Serial No.

Nitrification Field: No Fields 1 Square Feet ~~X~~ 840 Linear Feet 280

No Lines ~~3~~ 4 Trench Width ~~X~~ 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III ☒IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:

~~X~~ PER PLAN Specs

Comments/Conditions: 4 @ 70° x 2 PPBPS

5/32" holes;

12/19/07 Set 25ft pressure, checked float & alarm

INITIAL SITE SKETCH

SEE PLAN FROM ROWANS SOIL & ENV. SERVICES

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: date 10-26-06

Authorization to Construct by: Wesley Sparks RS. date 10-16-06

HEALTH DEPT. COPY: WHITE

Installed by: C+S Grading

Operation Permit by: Wesley Sparks RS. date 4/11/07

Existing System Inspection by: date 12/20/07

OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK