IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134426 PIN# ~~4649-04-9474-000~~ 4649-05-9071 DATE October 16, 2006

OWNER OR APPLICANT ~~Redwood Farms LLC~~ TEGLAND BROWN PHONE: Business _____ Home _____

ADDRESS 227 Hideaway Lane Mooresville, N.C. 28117

LOCATION North Rd (N) past Judas Rd - TR Wells Cherry Lane TL Orchard Farm Lane 6th Lot on left

SUBDIVISION The Orchard BLOCK / SECTION _____ LOT 6 LOT AREA 26,281 sq ft SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3 initial .25 Repair

Septic Tank: 1000 Gallons; STB 1012 Date 3/12/07

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4@100 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I ☒ III IV V VI

System Description: Gravity 25% Reduction "accepted"

Repair System Description: LPP PBPS

Maintenance Agreement Required: ☐ Yes ☒ No

Gravel Depth NA ☒ Gravity ☐ Pressure

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons ____

☐ Business No. Employees ____

☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 10-26-06 Installed by: C+S Grading

Improvement Permit by: _____ date 10-16-06 Operation Permit by: Wesley Sparks RS date 9/17/07

Authorization to Construct by: Wesley Sparks RS. date 4/3/07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK