4649 05 9160

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134430 PIN# 4649 04 9474.007 DATE October 16, 2006

OWNER OR APPLICANT Orchard Farms LLC / TEGLAND - BROWN PHONE: Business _____ Home _____

ADDRESS 227 Hideaway Lane, Mooresville NC 28117

LOCATION Both Rd (W) past Julian Rd TR Wild Cherry Lane TL Orchard Farm Lane 7th lot on left

SUBDIVISION The Orchard BLOCK / SECTION _____ LOT 7 LOT AREA 27575 ft² SITE CLASS. PS DESIGN FLOW 460gpd L.T.A.R. e3 with 1/.25 Repair

Septic Tank: 1000 Gallons; STB 101 gal Date 10/19/06

Pump Tank: 1000 Gallons; PT PT17 Date 5/27/07

Pump Make: Goulds Model WE6-511H Serial No. _____

Nitrification Field: No Fields 1 Square Feet * 855 Linear Feet 285 *

No Lines 4 Trench Width * 36" Max Trench Bottom Depth 36"

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI

System Description: LP PPBDS

Repair System Description: LP PPBDS

Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home No. Bedrooms 4

[ ] Mobile Home No. Persons ___

[ ] Business No. Employees ___

[ ] Other _____

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth NA [ ] Gravity [X] Pressure [ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions:

* PER plan specs

Comments:/Conditions:

Fees Due before OP $175

3 1/2" base

17
17
16
16

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 10-26-06 Installed by: _____

Improvement Permit by: _____ date 10-16-06 Operation Permit by: _____ date 6/19/08

Authorization to Construct by: _____ date 5-9-07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK