IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

100.00 Paid

PERMIT# 17774 PIN# 4639 96 2769 . 38 464906045 DATE 10/17/05

OWNER OR APPLICANT Lewis Carpenter PHONE: Business 704-634-5183 Home

ADDRESS PO Box 690027 Charlotte NC 28227

LOCATION Perth N TL / ST Honeysuckle Creek LP, L corner lot 4 and 3RD lot on (R)

SUBDIVISION Honeysuckle Creek BLOCK / SECTION LOT 38+38A LOT AREA 1.22 + .49A SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25 (38A)

Septic Tank: 1000 Gallons; STB 317 Date 3/7/69
Pump Tank: 1000 Gallons; PT 27 Date 2/22/69
Pump Make: Conolift Model WG-512 Serial No. C078505
Nitrification Field: No. Fields ~~Square Feet~~ Shannon Linear Feet 480
No Lines 4@120' Trench Width 3' Max ~~Trench Bottom~~ Depth 3'

[X] New System [ ] Repair [ ] Expansion System Type: I II (III) IV V VI
System Description: PM - 25% Reduced
Repair System Description: LP - 16" PBPS
Maintenance Agreement Required: [ ] Yes [X] No


[X] House/Mod. Home No. Bedrooms 4
[ ] Mobile Home No. Persons 4
[ ] Business No. Employees
[ ] Other

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth No [ ] Gravity [X] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments/Conditions:

INITIAL SITE SKETCH



Comments/Conditions:


The proposed / existing POOL addition does not appear to impact the existing septic system.

**NOTE: MUST BE 15' (SEPTIC) TO WATERS EDGE

R.S. 34-008

Date: APPROVED JUL 07 2014
ICHD-Environmental Health Division

ENTERED



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [ ] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Lewis Carpenter date 2-10-06 Installed by: Larry Beacom

Improvement Permit by: Wesley Sparks RS. date 10/20/05 Operation Permit by: Wesley Sparks RS. date 8/24/07

Authorization to Construct by: Wesley Sparks RS date 10/20/05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK