N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Honeysuckle Creek LLC APPLICATION DATE _____
DDRESS: _____ DATE EVALUATED: _____
ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
OCATION OF SITE: Honeysuckle Creek lot 38 PROPERTY RECORDED: _____
'ATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
VALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
YPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 6-9%	0-3	BSCL GR	fr SSSP SS-P	2 chroma @ 16"	15"	–	15"	(4)
		3-24	BRC ABK	fr SP SS-P					
		24-55	BR/C more fr SCL SS-P						
2		0-44	YBC ABK	fr SP –	2 chroma @ 18" T			18"	(4)
3		0-30	YR/RC ABK	fr SP – few	YBS		–	30"	.2-.25 @ < 32"
		30-57	YR/RC/RY more firm	SP – many YBS 2 chroma @ 32"					
4		0-25	YRC ABK	fr SP – many	YBS 2 chroma @ 18"	–	–	18"	(4)
		25-60	YBC/RY more fr SP						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____