DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Honeysuckle Creek LLC APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Honeysuckle Creek lot 1 PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 2-4%	0-5	BSiCL GR	fr: SSSP					
		5-54	RC ABK	f: SP - few YB mottles		54"	N/A	N/A	PS .25
			✱ Very heavy clays ✱						
2		0-6	BSiCL GR	fr: SSSP					
		6-43	RCL/SiCL WSBK	fr: SSSP - common rock		A SAP 43"	VS	N/A	PS .3
		43-60	SL SAP WSBK	fr: SSSP					
3		0-4	Loam GR	fr: SSSP					
		4-40	RC ABK	f: SP - few YB's		40"	(4)	40" Mott to CL SAP	PS .25 to .40
		40-52	RBCLSAP	f: SP					
			✱ Very heavy clays ✱						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bruce
OTHER(S) PRESENT: ___