4649069777

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Odell Stamey DATE 9/24/87 PERMIT NO.

PHONE: Business Home

LOCATION Perth Rd, Rt on Paved Rd before 1300, Lot on Lf near end S. R. No.

SUBDIVISION NAME SES Properties LOT NO. 11 SECTION OR BLOCK NO.


House ( ) Mobile Home (✓) Business ( ) Other Doublewide

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( ) Well area
Lot Area 1/2 acre+

Character & Porosity of Soil clay
Percolation Rate ~ 0.35 gpd/ft²
Topography 2-4%
Depth to Water Table
Rock or other impervious formations none noted

Basement with Plumbing MH Area Basement without Plumbing No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 1029 Linear Ft. 343
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY David Hargis

COMMENTS: Paved ROAD
Keep well 50' from tank & lines

CERTIFICATE OF COMPLETION BY DATE 9/24/87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold