3:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134659 PIN# ~~4649-04-4494.022~~ 4649 14 1355 DATE October 18, 2006

OWNER OR APPLICANT Richard Farms LLC / Lakeshore PHONE: Business _____ Home _____

ADDRESS 277 Hideaway Lane, Mooresville N.C. 28117

LOCATION Neil Rd (W) past Julian Rd TR Wild Cherry Lane on left past Richard Farm Lane

SUBDIVISION The Orchard BLOCK / SECTION _____ LOT 22 LOT AREA 48960 sq ft SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .25

Septic Tank: 1000 Gallons: STB 7600 Date 8-26
Pump Tank: 1000 Gallons: PT 3603 Date 12-20
Pump Make: GOULDS Model WE05511HH Serial No. _____
Nitrification Field: No Fields 1 Square Feet 990 ✱ Linear Feet 330 ✱
No Lines 3 Trench Width 36" ✱ Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LP PPBBS
Repair System Description: LP PPBBS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:
✱ Per Plan Specs
SEE Adjusted well location. It must be at least 25' behind house and 50'+ from septic supply lines.

Comments:/Conditions: 4/14/14 Checked pressure 2PT's
Heat & alarm ✓
✱ Maintenance Contract Received 4-16-14 AZP

INITIAL SITE SKETCH

SEE PLAN From Rollins Soil & Env. Services

AS BUILT SKETCH

CHECKED MAR 11 2014

LINES INSTALLED AS SHOWN
TANKS
CUB
BA 3@10'

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 10-26-06 Installed by: CHUB GUNTER

Improvement Permit by: _____ date 10-18-06 Operation Permit by: _____ date 4-16-14

Authorization to Construct by: _____ date 11-5-13 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK