IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 136600 PIN# 4649 ~~04 94 74 6023~~ 14-2216 DATE October 18, 2006

OWNER OR APPLICANT Orchard Farms LLC PHONE: Business _____ Home _____

ADDRESS 227 Hideaway Lane Mooresville, N.C. 28117

LOCATION Perth Rd (N) past Julian Rd 4R Wild Cherry home on left near end

SUBDIVISION The Orchard BLOCK / SECTION _____ LOT 23 LOT AREA 56,330 ft² SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. 3

Septic Tank: 1000 Gallons; STB 760 Date 3-8-13
Pump Tank: 1000 Gallons; PT 363 Date 11-2-13
Pump Make Goulds Model WE1012H Serial No. _____
Nitrification Field: No Fields 1 Square Feet 960 * Linear Feet 320 *
No Lines 5 Trench Width 36" * Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI
System Description: 4P PPBPS
Repair System Description: 4P PPBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:
* PER PLAN SPECS
* Must Keep Septic at least 5Ft from Building and 50ft from Creek/Branch

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

Comments:/Conditions: * Checked Lines ALP 5-29-14
6/19/14 Set 2Ft Pressure, Checked of Elect & Alarm MZ

AS BUILT SKETCH

The proposed / existing Garage addition does not appear to impact the existing septic system.
**NOTE: Must Keep Building 5Ft from Septic & Keep Septic at least 50ft from Branch
Date: 5/21/14
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 10-26-06 Installed by: Gunter Grading

Improvement Permit by: _____ date 10-18-06 Operation Permit by: _____ date 7-1-14

Authorization to Construct by: _____ date ~~10~~ 2-11-14 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK