1:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134522 PIN# 4649049474 4649-15-2066 DATE October 17, 2006

OWNER OR APPLICANT Orchard Farms LLC / Pride Homes PHONE: Business _____ Home _____

ADDRESS 223 Hideaway Lane, Mooresville, N.C. 28117

LOCATION Perth Rd (W) past Dulin Rd TR Wildcherry Lane TL Orchard Farm Lane 7th on Right

SUBDIVISION The Orchard BLOCK / SECTION _____ LOT 15 LOT AREA 30,216 ft² SITE CLASS. RS DESIGN FLOW 440gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; STB 1012 Date 2/24/07
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400
No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: Gravity 25% Reduction accepted
Repair System Description: LPP PPBPS
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons ____
☐ Business No. Employees ____
☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:
- Quick 73
- Yellow Poly-lok filter
- 1 @ 10P
- 5 speed leveler set

INITIAL SITE SKETCH

See Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 10-26-06 Installed by: C&S Grading

Improvement Permit by: _____ date 10-17-06 Operation Permit by: _____ date 7/11/07

Authorization to Construct by: _____ RS date 4/11/07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK