4649 15 3182

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134507 PIN# 4649 04 9474 . 014 DATE October 19, 2006

OWNER OR APPLICANT Orchard Farms LLC, P. Poole PHONE: Business _____ Home _____

ADDRESS 227 Hideaway Lane, Mooresville, N.C. 28117

LOCATION Faith Rd (N) past Judas Rd TR Wild Cherry Lane TL Orchard Farm Lane

SUBDIVISION The Orchard BLOCK / SECTION _____ LOT 14 LOT AREA 1.65Ac SITE CLASS. AS DESIGN FLOW 360gpd L.T.A.R. e3

Septic Tank: 1000 Gallons; STB 1012 Date 3/19/07

Pump Tank: 1000 ✓ Gallons; PT 17 Date 5/11/07

Pump Make: Ecoflo Model ~~ES-702HH~~ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 621 ✱ Linear Feet 207 ✱

No Lines 3 Trench Width 36" ✱ Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons _____ No. Employees _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:

✱ PER Plan Specs

Drive on opposite side, tanks on left side PBP house

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

Comments/Conditions: 69-69-69 installed

9/10/07 Tanks & lines Checked by WS

12/19/07 JA pressure set, Checked effect & alarm

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 10-26-06 Installed by: C & S Const

Improvement Permit by: _____ date 10-19-06 Operation Permit by: Wesley Sparks R.S. date 12/20/07

Authorization to Construct by: Wesley Sparks R.S. date 4/11/07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK