IREDELL COUNTY HEALTH DEPARTMENT 4649169949

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frank E. White DATE 5-25-83 PERMIT NO. 163

PHONE: Business _____ Home _____

LOCATION 150W TR 1303 / TR 1300 ½ mile on R before Junction w/ 1313 S. R. No. _____

SUBDIVISION NAME R. F. Duncan Prop. LOT NO. 10 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Character & Porosity of Soil Clay loam / Clay
Percolation Rate 2-5 MPI / 0 / 2-5 MPI / clay
Topography 2-8%
Depth to Water Table 4'+
Rock or other impervious formations None observed

Lot Area 2 1/2 ACRES

Basement with Plumbing _____ Basement without Plumbing _____ No Basement X




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1080 Linear Ft. 360'
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Donald Lockey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer (REHS)

COMMENTS: Installed 9' x 120' [redacted] instead of 2 - 120' x 3' trench system

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-25-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold