DIVISION OF ENVIRONMENTAL HEALTH — NATURAL RESOURCES
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Conn Thean Deal
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: SFR APPLICATION DATE: ___
LOCATION OF SITE: Lot 7 The Ramblers PROPOSED DESIGN FLOW (.1949): Stnd DATE EVALUATED: Jun 5 20
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other PROPERTY SIZE: ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1		0-5	wk sbk fr sl cl	fr					
		5-25	md sbk RC	fr sp sss sp stp					
		25-48	wk mk sbk RCL	fr ss sb	few mi stp				.3
		48-68	wk fsbk yr cl/L	fr ss sp	few - common mi sp				
2	5%	0-8	gr fine sd	fr ss p					
		8-32	mk sbk rc	fr ss sp	few brn/bl mottles				.25
		32-60	wk fsbk rcl	fr ss sp	common mi sp				
3		0-6	gr fine sd	fr ss p					
		6-22	mk sbk rc	fr sp sss p stp					
		22-43	wk mk sbk rc	fr fr sp ss p					.25
		43-67	(65-0) wk fsbk yr cl/L	fr ss sp	few red/bl mottles				.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv/25% Red	Pumped/25-50% Red
Site LTAR	.125	.125

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DBA
OTHER(S) PRESENT: ___