4649260999

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eagle Home Builders DATE 9-16-82 PERMIT NO. 296

PHONE: Business _____ Home _____

LOCATION 1303 N. TR 1300 on Rt across from 1313

S. R. No. _____

SUBDIVISION NAME RF Overcash property LOT NO. 11 East SECTION OR BLOCK NO. 1
Lot Pt 10


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-8%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Unk.	
			Rock or other impervious formations	none obs.	

Lot Area 1 Ac.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 150 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Eddie Young

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: _____


CERTIFICATE OF COMPLETION BY [signature] DATE 9-16-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold



4649260999

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eagle Home Builders DATE 9-16-82 PERMIT NO. 246

PHONE: Business _____ Home _____

LOCATION 1303 N. TR 1300 on Rt across from 1313

_____ S. R. No. _____

SUBDIVISION NAME RF Overcash property LOT NO. 11 East SECTION OR BLOCK NO. 1

Lot Pt 10

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay loam
Percolation Rate 30
Topography 6-8%
Depth to Water Table unk.
Rock or other impervious formations more otz.

Lot Area 1 Ac.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 150 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Eddie Young

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JAC

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Jack R. Hinson DATE 9/16/82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

