IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joseph Moore, Jr. DATE 10-20-82 PERMIT NO. 322

PHONE: Business _____ Home _____

LOCATION 150 W SR 1303 SR 1300 0.5 Mile on R across from junction w/ 1313 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate	60 MPI @ 18"
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Gently Rolling
Site Suitable	Yes (X)	No ( )	Depth to Water Table	Unknown
			Rock or other impervious formations	None observed

Lot Area 2.01 ACRES

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1000 Linear Ft. 333'
Depth of Stone in Lines 10"

Water Supply: Individual X
Public ( )

Statesville

Installed by Gene Duncan

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Tank deep (3') on House end
No driving to be done over system – scattered Rock outcroppings

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 10-20-82
EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold