4649 27 0987

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hayward Const Co DATE 4-8-94 PERMIT NO. 248

PHONE: Business _____ Home _____

LOCATION 1202 D. TB on 1300 blk of Lake Nor. on Left _____ S. R. No. _____

SUBDIVISION NAME Kings Point LOT NO. 43 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )

Lot Area 20,000 Sq Ft

Character & Porosity of Soil Clay Loam Loamy Fine
Percolation Rate 60 min/in
Topography Slope
Depth to Water Table 4'6"
Rock or other impervious formations Rock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 330 Linear Ft. 330
Depth of Stone in Lines 24"
Water Supply: Individual ( )
Public ( )

Installed by Lewis

IMPROVEMENTS PERMIT BY J. P. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [illegible] DATE 4-27-94

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold