DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kent Salyer
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: SFR APPLICATION DATE: ___ DATE EVALUATED: Jan 6 05
LOCATION OF SITE: Lot 2 The Ranches PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-15	wf sbk & rc	fr ss sp-sspl	SAP				.3
		15-48	wk fsbk rcl	fr ss sp					
		48-58	wk fsbk - massive L SAP	fr ss sp ln s sp					
2	4-6% S/L	0-24	mod fsbk rc	fr sss sp	SAP				.3
		24-38	wk fsbk rcl	fr sss sp	slightly mottled sap				
		38-57	massive L/sil	sap	fr ss sp				
3		0-3	wk sbk s/w scl/l	fr ss sp					.25-.3
		3-24	mod fsbk rc	fr sss sp	SAP				
		24-57	(2-c) wk fsbk cyrcl	fr sss sp	common mod SAP & few-w. mott				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	RS	RS
System Type(s)		LPPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: DHH
OTHER(S) PRESENT: ___
see plat for pot location