4649-27-7957

IREDELL COUNTY HEALTH DEPARTMENT

11289

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy McDowell DATE June 15, '90 PERMIT NO. 3F6A22

PHONE: Business _____ Home _____

LOCATION 1303 N TR 1300 (Fern Hill) TR 1313 Carlyle TL into Kings Acres on left corner lot w/ 1st Street to left S. R. No. _____

SUBDIVISION NAME Kings Acres LOT NO. 22 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1-2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable PS Yes (✓) No ( )

Lot Area 135 X 180' Existing


Character & Porosity of Soil PS Clay

Percolation Rate mod

Topography rolling

Depth to Water Table 4'+

Rock or other impervious formations none Obs



_____ Basement with Plumbing ___0___ Basement without Plumbing ___✓___ No Basement

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓ CW

Installed by Owner

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 6-15-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold