4649 28 0147

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jimmy Williams DATE 4-18-80 PERMIT NO. 83

PHONE: Business _____ Home _____


LOCATION 21N TL 1312, TL 1313, TR 1477 (Entrance to King's Acres TL 1st Street TR at Stop Sign on left S. R. No. _____

SUBDIVISION NAME King's Acres LOT NO. 7 11 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate	50 MPI	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	2-8%	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	unknown	
Lot Area 20,000 ft²			Rock or other impervious formations	None observed	



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (X)
Community H2O

Installed by Wm Cuthbertson

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-18-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold