DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: Crin Hand Dev. APPLICATION DATE _____
ADDRESS: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360gpd DATE EVALUATED: 11-18-8
LOCATION OF SITE: Lot 2 Tanglewood PROPERTY SIZE: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-16	gr-wk fsbk sl	fr sss p					.25
		16-39	m fsbk RC	fi sl sspl sspl					
		39-61	w/k fsbk RCL	fr sss p	Ter mi sap @ lower pt 3) hoagin				
2	4-6%	0-4	slightly compacted w/k fsbk	fr sss p					.25-.3
		4-24	m fsbk RC	fr SDSspl					
		24-49	BW wk fsbk mod	fr sss p	common in sap				
		49-68	massive LSap	fr sss p					
3		0-5	wk fsbk sl blky	fr sss p					.25-.3
		5-26	m fsbk RC	fr SDSspl					
		26-41	BW wk fsbk mod	fr sss p	common in sap				
		41-68	massive LSap	fr sss p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pm 25% Red	LPP80%
Site LTAR	.25-.3	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JRH
OTHER(S) PRESENT: _____

COMMENTS: _____