DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Darnell Long APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7/24/08
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Carlyle Rd PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	2-4%	0-12"	Rd/Brn C/L	SBK SS, SPSE, FFR	w/few to many SAP inclus				PS.
		12-48"	Yel/Brn SL	SAP					
		have to evaluate in Backpits							
2	Repair	0-6"	Brn SL	GR FR					PS .3
		6-36"	Rd/Brn C/L	FR SE, FI	w/few to many SAP inclus				
		36-48"	SAP/C	mix					
3	Initial	0-42"	Rd/Brn C/L	SBK SS, SPSE, FI FR	w/few to many SAP inclus				PS .3+
4	Initial	0-40"	Rd/Brn C/L	SBK SS, SPSE, FI FR	w/few to many SAP inclus				PS .3
		40"	SL SAP						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____