DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 2R -K- 27
PROPERTY RECORDED: YES
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: TIMOTHY R TAYLOR OWNER: AGENT: PHONE: 392 - 8609
ADDRESS: 8828 LARKHAVEN RD. APPLICATION DATE: 7/15 DATE EVALUATED: 7/16
CHARLOTTE, NC. PROPOSED FACILITY: 3BD - 2BA
PROPERTY SIZE: ~ 8.9 AC
LOCATION OF SITE: RANKIN HILL RD, ON (R) JUST BEFORE I-77
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS 3-5%	0-5	1/M/CR/L	1:1	WSO-WPO	No	S	—	
		6-17	3/M/sbk/C	1:1	WS-WP	No	P	—	
		18-25	3/C/wk sbk/C	1:1	WS-WP	No	P	—	
		26-43	3/C/sbk/C	1:1	WSS-WP	No	P		.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: SPARKS OTHER(S) PRESENT: TIM TAYLOR
COMMENTS: COARSE - STRONG SBK STRUCTURE — 36" DEPTH TRENCHES