DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 16503
PROPERTY RECORDED: ___
COUNTY: FREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: J WAYNE NEILL JR. OWNER: ✓ AGENT: ___ PHONE: 663-1697
ADDRESS: BARFIELD RD. APPLICATION DATE: 6/14/93 DATE EVALUATED: 6/14/93
PROPOSED FACILITY: 3BD - 2BA HOUSE
PROPERTY SIZE: ~ 2 AC.
LOCATION OF SITE: END OF BARFIELD RD. ON ℄
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	~~0-8~~ S	0-8	S sbk F / c l	1:1	S	S	S	N/A	
	S	9-19	S sbk F / c	1:1	S	S	S	N/A	
		20-23	sbk VF / c	1:1	S	S	S	P	
		24-36	w sbk VF / c	1:1	S	S	S	P	
		37-43	w sbk-TR VF / c	1:1	S	S	II	P	.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: Sparks OTHER(S) PRESENT: WAYNE NEILL JR & JR.
COMMENTS: OPEN FIELD, 3 PLOW TERRACES TO BE SMOOTHED DOWN.