IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 17165 PIN # ~~4649 80 6910.001~~ DATE March 8, 2012 4649807667

OWNER William Torrence APPLICANT: same PHONE: Home/Cell # Business #

SITE ADDRESS Barfield Rd. Mooresville NC 28115 OWNER / APPLICANT ADDRESS 509 North Church Street Mooresville NC 28115

SITE DIRECTIONS Hwy 21 N TL Barfield on right

SUBDIVISION BLOCK / SECTION LOT # LOT AREA 1.35 Ac. DESIGN FLOW 360 gpd L.T.A.R. .3 gpd/ft²

Septic Tank 1000 Gallons: STB 312 Date 4-21-12

Pump Tank Gallons: P T Date

Pump Make Model Serial #

No. Nitrification Fields: 1 No. Lines 3 Linear Feet 300

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25% Reduction Gravity

Repair System Description: 25% Reduction Gravity

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

Shave berm before installing system

☆ Property shall be Recorded by Reg. of Deeds

INITIAL SITE SKETCH

Before AC

Follow plan

submitted by

Rollins Soil & Environmental

Services

Approved by ICHD

AS BUILT SKETCH

INSTALLED AS SHOWN

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** with plat valid without expiration. ☒ ***IMPROVEMENT PERMIT*** with plat valid without expiration. site plan valid 60 mo. ☐ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: James C. Torrence Jr. Date 3-8-12 Installed by: Ashley Rollins

IMPROVEMENT PERMIT by: Judy Melville REHS Date 3-8-12 OPERATION PERMIT by: REHS Date 6-4-12

AUTHORIZATION TO CONSTRUCT by: Judy Melville REHS Date 3-12-12 Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant