VISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Pruitt Dev. Co. APPLICANT: _____
DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9/17/98
ROPOSED FACILITY: 3BD-2BA PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
OCATION OF SITE: Linwood Pointe PROPERTY RECORDED: _____
'ATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
VALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
YPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 10% R-RL Top (154)	0-7	MFGR / l	SS NP	S				
		8-15	2 MFGR / cl	SS NP					.3
		16-21	3 SC SBK / cl	SS SP					
		22-31	2 MMGR / cl SAP	SS SP					.35
		32-50	3 SmGR / MIC l SAP	SS NP	S	S	PS	NF	
2	LS 10% Bottom (154)	0-7	MMGR / sl	FR NS NP					
		8-16	SMSBK / cl	FI SS SP					.3
		17-24	MF SBK / scl	FI SS SP					
		25-40	MMGR / scl	VFR SS NP	S	PS	PS	40R	.35
		41	FLOATER (R)						
3	Top T (161)	0-7	SFGR / gsl	FI SS NP					
		8-12	MMSBK / cl	FI SS SP					.3
		13-24	MMSBK / cl	FR SS SP	S	PS	PS	NF	
		25-50	SMGR / cl SAP	SS NP					.35
4	(161)								

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		
ystem Type(s)		
te LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____