DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 4 bedroom PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Windward pt 127 PROPERTY RECORDED: _____
WATER SUPPLY: • Private • Public • X Well • Spring • Other _____
EVALUATION METHOD: • Auger Boring • X Pit • Cut TYPE OF WASTEWATER: X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
7	5%	0-8	Brsl gr	Fr ss sp	—	59"	—	—	PS
		8-23	Rc sbk	Fr ss sp					0.3
		23-29	Brsclwsbk	Fr ss sp					
		29-59	Rc sbk	Fr ss sp					
8	7%	0-11	Brsclwsbk	Fr ss sp	—	58'	Few fem sap common fine sap	—	PS
		11-34	Rc sbk	Fr ss sp					0.3
		34-41	Rsclwsbk	Fr ss sp					
		41-58	4R sclwsbk	Fr ss sp					
	12%	0-15	Brsclwsbk	Fr ss sp	—	54"	common fine sap	—	PS
		15-39	Rc sbk	Fr ss sp					0.3
		39-54	Rsclwsbk	Fr ss sp					
10		54-60	sl sap gr	Fr ss sp			PS		
	15%	0-16	Brsclwsbk	Fr ss sp	—	55"	common fine sap	—	PS
		16-49	4R c/cl sbk	Fr ss sp					0.3+
9		49-55	Rsclwsbk	Fr ss sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 ft²	540 ft²
System Type(s)	25% Red	PP CPS
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: MA + Assoc.
OTHER(S) PRESENT: _____

COMMENTS: _____